

Prüfprotokoll OGM^{plus}

Oval gear meter PLUS 04500

PN: **280046**



OGM PLUS 04500VCFPPKKE-G5/4I-99-0050m-P

materials of construction: PVC, FPM, PEEK, ceramic

signal output (standard): 50.0 ml/pulse, 20 pulses/l

max. pump size: 450 / 540 l/h (50/60Hz)

semiconductor junction: PNP

prod. code: 02/481471 /33822 /1004

ECOLAB Engineering GmbH
D-83313 Siegedorf



Anlaufgrenze 75 [l/h]*
lower measuring range limit

Impulszahl 41 [n/min]
pulse rate

bei 120 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 21.09.22

Prüfer P3

Prüfprotokoll OGM^{plus}

Oval gear meter PLUS 04500

PN: **280078**

OGM PLUS 04500VCEPPKKE-G5/4I-99-0050m-P

materials of construction: PVC, EPDM, PEEK, ceramic

signal output (standard): 50,0 ml/pulse, 20 pulses/l

max. pump size: 450 / 540 l/h (50/60Hz)

semiconductor junction: PNP

prod. code: 02/484730/33822/1003

ECOLAB Engineering GmbH
D-83313 Siegedorf



Anlaufgrenze 75 [l/h]*
lower measuring range limit

Impulszahl 40 [n/min]
pulse rate

bei 120 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 21.09.22

Prüfer P3

Prüfprotokoll OGM^{plus}

Oval gear meter PLUS 04500

PN: **280078**

OGM PLUS 04500VCEPPKKE-G5/4I-99-0050m-P

materials of construction: PVC, EPDM, PEEK, ceramic

signal output (standard): 50,0 ml/pulse, 20 pulses/l

max. pump size: 450 / 540 l/h (50/60Hz)

semiconductor junction: PNP

prod. code: 02/484730/33822/1004

ECOLAB Engineering GmbH
D-83313 Siegedorf



Anlaufgrenze 75 [l/h]*
lower measuring range limit

Impulszahl 41 [n/min]
pulse rate

bei 120 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 21.09.22

Prüfer P3