



Prüfprotokoll OGM^{plus}

Oval gear meter PLUS 00540	
W3T262907	
OGM PLUS 00540VCFPPKKE-G1/4I-99-0820p-P	
materials of construction:	PVC, FPM, Peek, ceramic
signal output (standard):	1.22 ml/pulse, 0820 pulses/l
max. pump size:	54 / 65 l/h (50/60Hz)
semiconductor junction:	PNP
prod. code:	00 / 712889 / 20923 / 1001
ECOLAB Engineering GmbH D-83313 Siegedorf	

Anlaufgrenze 6 [l/h]*
lower measuring range limit

Impulszahl 145 [n/min]
pulse rate

bei 10 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow .

Datum 3.03.23

Prüfer P 421

Prüfprotokoll OGM^{plus}

Oval gear meter PLUS 00540	
W3T202907	
OGM PLUS 00540VCFPPKKE-G1/4I-99-0820p-P	
materials of construction:	PVC, FPM, Peek, ceramic
signal output (standard):	1,22 ml/pulse, 0820 pulses/l
max. pump size:	54 / 65 l/h (50/60Hz)
semiconductor junction:	PNP
prod. code:	00 / 712669 / 20923 / 1002
ECOLAB Engineering GmbH	
D-83313 Siegsdorf	

Anlaufgrenze 6 [l/h]*
lower measuring range limit

Impulszahl 152 [n/min]
pulse rate

bei 10 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 3.03.23

Prüfer P 421

Prüfprotokoll OGM^{plus}

Oval gear meter PLUS 00540

W3T22907

OGM PLUS 00540VCFPPKKE-G1/4I-99-0820p-P

materials of construction: PVC, FPM, Peek, ceramic

signal output (standard): 1,22 ml/pulse, 0820 pulses/l

max. pump size: 54 / 65 l/h (50/60Hz)

semiconductor junction: PNP

prod. code: 00 / 712889 / 20923 / 1003

ECOLAB Engineering GmbH
D-53313 Sieglar



10071



Anlaufgrenze 6 [l/h]*
lower measuring range limit

Impulszahl 144 [n/min]
pulse rate

bei 10 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 3-03-23

Prüfer P 421

Prüfprotokoll OGM^{plus}

Oval gear meter PLUS 00540
W3T262907 
OGM PLUS 00540VCFPPKKE-G1/4I-99-0820p-P
materials of construction: PVC, FPM, Peek, ceramic
signal output (standard): 1,22 ml/pulse, 0820 pulses/l
max. pump size: 54 / 65 l/h (50/60Hz)
semiconductor junction: PNP
prod. code: 00 / 712686 / 20923 / 1004

ECOLAB Engineering GmbH
D-83313 Slegsdorf 

10071

Anlaufgrenze 6 [l/h]*
lower measuring range limit

Impulszahl 150 [n/min]
pulse rate

bei 10 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 3.03.23

Prüfer P 421

Prüfprotokoll OGM^{plus}

Oval gear meter PLUS 00540		
W3T262907		
OGM PLUS 00540VCFPPKKE-G1/4I-99-0820p-P		
materials of construction:	PVC, FPM, Peek, ceramic	10071
signal output (standard):	1.22 ml/pulse, 0820 pulses/l	
max. pump size:	54 / 65 l/h (50/60Hz)	
semiconductor junction:	PNP	
prod. code:	00 / 712889 / 20923 / 1005	
ECOLAB Engineering GmbH D-83313 Siegedorf		

Anlaufgrenze 6 [l/h]*
lower measuring range limit

Impulszahl 147 [n/min]
pulse rate

bei 10 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 3.03.23

Prüfer P 421

Prüfprotokoll OGM^{plus}

Oval gear meter PLUS 00540

W3T202907

OGM PLUS 00540VCFPPKKE-G1/4I-99-0820p-P

materials of construction: PVC, FPM, Peek, ceramic
signal output (standard): 1,22 ml/pulse, 0820 pulses/l
max. pump size: 54 / 95 l/h (50/60Hz)
semiconductor junction: PNP
prod. code: 00 / 712000 / 20923 / 1008

ECOLAB Engineering GmbH
D-63313 Siegedorf



10071



Anlaufgrenze 6 [l/h]*
lower measuring range limit

Impulszahl 147 [n/min]
pulse rate

bei 10 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 3.03.23

Prüfer P 421

Prüfprotokoll OGM^{plus}

Oval gear meter PLUS 00540	
W3T262907	
OGM PLUS 00540VCFPPKKE-G1/4I-99-0820p-P	
materials of construction:	PVC, FPM, Peek, ceramic
signal output (standard):	1,22 ml/pulse, 0820 pulses/l
max. pump size:	54 / 65 l/h (50/60Hz)
semiconductor junction:	PNP
prod. code:	00 / 712588 / 20923 / 1007
ECOLAB Engineering GmbH	
D-63313 Siegbach	

Anlaufgrenze 6 [l/h]*
lower measuring range limit

Impulszahl 146 [n/min]
pulse rate



bei 10 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 3.03.23

Prüfer P 421

Prüfprotokoll OGM^{plus}

Oval gear meter PLUS 00540		
W3T262907		
OGM PLUS 00540VCFPPKKE-G1/4I-99-0820p-P		
materials of construction:	PVC, FPM, Peek, ceramic	10071
signal output (standard):	1.22 ml/pulse, 0820 pulses/l	
max. pump size:	54 / 65 l/h (50/60Hz)	
semiconductor junction:	PNP	
prod. code:	00 / 712889 / 20923 / 1008	
ECOLAB Engineering GmbH D-83313 Siegsdorf		

Anlaufgrenze 6 [l/h]*
lower measuring range limit

Impulszahl 152 [n/min]
pulse rate


bei 10 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 3.03.23

Prüfer P 421

Prüfprotokoll OGM^{plus}

Oval gear meter PLUS 00540		
W3T262907		
OGM PLUS 00540VCFPPKKE-G1/4I-99-0820p-P		
materials of construction:	PVC, FPM, Peek, ceramic	10071
signal output (standard):	1,22 ml/pulse, 0820 pulses/l	
max. pump size:	54 / 65 l/h (50/60Hz)	
semiconductor junction:	PNP	
prod. code:	00 / 712699 / 20923 / 1009	
ECOLAB Engineering GmbH D-83313 Siegedorf		

Anlaufgrenze 6 [l/h]*
lower measuring range limit

Impulszahl 140 [n/min]
pulse rate

bei 10 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 3.03.2023

Prüfer P 421

Prüfprotokoll OGM^{plus}

Oval gear meter PLUS 00540

W3T202907

OGM PLUS 00540VCFPPKKE-G1/4I-99-0820p-P

materials of construction: PVC, FPM, Peek, ceramic
signal output (standard): 1,22 m/pulse, 0820 pulses/l
max. pump size: 54 / 65 l/h (50/60Hz)
semiconductor junction: PNP
prod. code: 00 / 712889 / 20023 / 1010



10071

ECOLAB Engineering GmbH
D-83313 Siegedorf



Anlaufgrenze 6 [l/h]*
lower measuring range limit

Impulszahl 140 [n/min]
pulse rate

bei 10 [l/h]*
at

* = kontinuierlicher Durchfluss / continuous flow

Datum 3.03.2023

Prüfer P 421